

22:06 Pakistan Time

Date & Time Of Print: 25/03/2022 22:06:46 - Time Zone: Pakistan Time Buyer Organisation: Pakistan Petroleum Limited

OVERVIEW

Code	rfq_21043
Title	PD/E&I/PP/21043/22 – Supply of air circuit breaker for new 600KW gas genset
Description	
Status	Running

RFQ SETTINGS

Online Response Required:	Yes	
Event Currency	PKR	
Allow Bidding Group Response	No	
Publication	22/03/2022 10:32:19	
Closing	07/04/2022 11:30:00	
Time Limit for Expressing Interest	07/04/2022 11:30:00	
Awarding Strategy	Best Price	

ATTACHMENTS

Path		Description	Folder Size	
root (5)			21,889 KB	
Filename	Downloadable	Last Modification Date	Description	File Size
Guidlines for Visitors.pdf	Yes	15/03/2022		18,958 KB
Instructions TCs For Procurement Of Materials.pdf	Yes	15/03/2022		393 KB
Instructions TCs For Procurement Of Services.pdf	Yes	15/03/2022		662 KB
Supplier User Guide – Responding to Online Tenders_1.pdf	Yes	15/03/2022		1,220 KB
Supplier User Guide - Using the Messaging Tool_1.pdf	Yes	15/03/2022		658 KB

ENVELOPES

Qualification Envelope	No
Technical Envelope	Yes
Commercial Envelope	Yes

TECHNICAL ENVELOPE

General Attachments	
Allowed	

TERMS:

Question	Description	Question Type
DELIVERY:	DELIVERY:	Text
BID VALIDITY	BID VALIDITY	Date

Question	Description	
NOTE	TE Below is the list of required items. Respond if you are quoting for same specs or a variant.	
Question	Description	Question Type
0010178104-99-00010	Specifications of Air Circuit Breaker We required complete ACB which covers complete frame, handle, and other accessories, complete in all aspect. Type: Air Circuit Breaker Cat No: MWI6123LEA13MWR1RR6YNNNAX Make: Cutler Hammer (Eaton) Standard: IEC 60947-2 Ampere Rating: 1250 A Frame: 1250 A No of Poles: 03 Frequency: 50/ 60 Hz Operating voltage: 480 VAC Ui: 1000 V Uimp: 8000V Icu: 65 KA @ 480 / 690 V Mounting: Draw out Motor Operated: 110 - 125 VAC 50/60 Hz ACB shall include the following accessories Parent Frame Nar. Type B IEC 3-Pole Levering Device Levering Mntg Parts Grp Rej. Brkt. MWN Rej Bracket Mounting Group Trip Unit Current Sensor 1250A Rating Plug 1250A Under voltage Relay Inst 208 / 240 AVC Spring Release kit: 208 / 240 VAC, 220 / 250 VDC Shunt Trip: 208 / 240 VAC, 220 / 250 VDC Breaker motor 110 - 125 VAC 50/60 Hz Trip Flag (pop-out indicator) 06 NO and 06 NC auxiliary contacts Primary Disconnect D/O Breaker Hold Down Plate HEX HD LAG SCREW Magnum ACB - Racking In/Out Tool - Draw out Handle. Bracket frame Racking handle Complete in all aspect Documents Required with Product Delivery Operation and Maintenance Manual Internal Wiring Diagram Technical Data Sheet Dimension and layout drawing with bid.	Option List

COMMERCIAL ENVELOPE

General Attachments	
Allowed	

TOTAL MATERIAL VALUE WITH SURCHARGES

Code	Description	Last PO No / Date / Item Remarks	Unit of Measurement	Quantity
	FOB /Packing Charges (If any)		LUMP SUM	1
	Freight (if any)		LUMP SUM	1

CONFIRM FOLLOWING AS PROVIDED IN THE BID

Question	Description	Question Type
Delivery Period	Delivery Period	Text
Bid Validity	Bid Validity (180 days)	Date
Delivery Terms	Delivery Terms	Text
Country of Origin	Country of Origin	Text
Port of Shipment	Port of Shipment	Text
Payment Terms	Payment Terms [LC / Advance / Net 30 days]	Text

LIST OF MATERIALS

Code	Description	Last PO No / Date / Item Remarks	Unit of Measurement	Quantity
	Specifications of Air Circuit Breaker We required complete ACB which covers complete frame, handle, and other accessories, complete in all aspect. Type: Air Circuit Breaker Cat No: MWI6123LEA13MWR1RR6YNNNAX Make: Cutler Hammer (Eaton) Standard: IEC 60947-2 Ampere Rating: 1250 A Frame: 1250 A No of Poles: 03 Frequency: 50/ 60 Hz Operating voltage: 480 VAC Ui: 1000 V Uimp: 8000V Icu: 65 KA @ 480 / 690 V Mounting: Draw out Motor Operated: 110 – 125 VAC 50/60 Hz ACB shall include the following accessories Par		EA	1
Sales / Services Tax %	Total (Inclusive Sales Tax)			
Section total included in	total?			Yes